



California Department of Forestry & Fire Protection
Office of the State Fire Marshal
PreFire Engineering
LISTING SERVICE

**Listing Expires
June 30, 1998**



LISTING No.

7165-0801:102

Page 1 of 1

CATEGORY:

Control Unit (Non High-Rise)

LISTEE:

Radionics, 1800 Abbott Street, Salinas CA 93901
Contact: Mark Hanna (408) 757-8877

DESIGN:

Model D8112 fire alarm control unit. Inherently power-limited; remote station, central station and local service. Refer to the listee's data sheet for component description and electrical rating. System components:

D8112A/-E/-G	Controller
D1252	Alpha II Station
D125B	Loop Interface
D105-FL	EOL Resistor
D129	Dual Class A Interface
D128	Dual Phone Switch
D192A/B/C	Bell Supervision
D126/*D1218	Battery
D8132	Battery Charger
D360/D360TD/D360-04/D510/D520A	Command Center
D1252/1252A	Alpha II Station
D1252A-04/D125TD	Command Station
D122	Battery Harness
D1640	Class 2 Transformer
D8109/D8004/D8108A	Enclosure
D8125	Zone Expander
D8127T/D8127U/*D9127T/*D9127U POPIT	Transponder
D8128	8-Zone POP Transponder
D8129	Octo Relay
D8130	Release Module
D8131	Serial Interface
D127/D136	Relay
D8114	Quad Serial Output
D8122	Derived Channel STU

INSTALLATION:

In accordance with the listee's printed installation instructions and applicable codes and ordinances.

MARKING:

Listee's name, model number, electrical rating and UL label.

APPROVAL:

Listed as fire alarm control unit for use with separately listed compatible initiating and indication devices. *D8127T, D8127U, D9127T and D9127U POPIT modules shall be used with four-wire smoke detectors only.

Rev. 09-18-95

This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

ISSUED: JULY 1, 1997

Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN O. HO**
Program Coordinator