



California Department of Forestry & Fire Protection  
Office of the State Fire Marshal  
PreFire Engineering  
**LISTING SERVICE**

**Listing Expires  
June 30, 1998**



**LISTING NO.**

7167-0801:104

Page 1 of 1

**CATEGORY:**

Control Unit (Household)

**LISTEE:**

Radionics, 1800 Abbott Street, Salinas CA 93901  
Contact: Mark Hanna (408) 757-8877

**DESIGN:**

Model D8112 residential combination fire/burglary system. This system is inherently power-limited. Refer to listee's data sheet for detailed product description and operational considerations. System components:

D8112A/E/G	Controller
D136	Relay
D126/*D1218	Battery
D8132	Battery Charger
D122	Battery Harness
D1252	Alpha II Arming
D8122	Derived Channel STU
D125B	Power Loop Interface
D1640	Class 2 Transformer
D105-FL	EOL Resistor
D129	Dual Class A
D128	Phone Line Switch
D192A/B/C	Bell Circuit Supervision
D8109/D8103/D8108A	Enclosure
D1251AF	Command Center
D8125	Zone Expander
D8127T/D8127U/*D9127T/*D9127U	POPIT Transponder
D8128	8 Zone POPIT Transponder
D8129	Octo Relay
D8130	Release Module
D8131	Printer Interface
D8114	Quad Serial Output

**INSTALLATION:**

In accordance with the listee's printed installation instructions and applicable codes and ordinances.

**MARKING:**

Listee's name, model number, electrical rating and UL label.

**APPROVAL:**

Listed for use as combination household fire/burglary control unit for use with listed compatible initiating and indicating devices. Models \*D8127T/U, D9127T/U, POPIT modules shall be used with 4-wire smoke detectors only.

**NOTE:**

Burglary and other non-fire functions were not examined.

\*Rev. 09-18-95

*This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.*

ISSUED: **JULY 1, 1997**  
Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN Q. HO**  
Program Coordinator