



California Department of Forestry & Fire Protection
Office of the State Fire Marshal
PreFire Engineering
LISTING SERVICE

**Listing Expires
June 30, 1998**



LISTING NO. 7167-0801:105

Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: Radionics, 1800 Abbott Street, Salinas CA 93901
Contact: Mark Hanna (408) 757-8877

DESIGN: Model D6112, power-limited household control unit. Refer to listee's data sheet for detailed product description and operational considerations. Basic components:

D6112	Control Panel
D610	Control Station
D620	Control Station/Zone Expander Module
D630	Control Station/Zone Expander Module
D640	Control Station/Zone Expander Module

INSTALLATION: In accordance with the listee's printed installation instructions and applicable codes and ordinances.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a household fire alarm control unit for use with separately listed compatible initiating and audible devices. Intended for use with Models D6000 or D6500 digital alarm receivers.

- NOTE:**
1. Burglary and other non-fire functions were not examined.
 2. Formerly 7165-0801:105

This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

ISSUED: JULY 1, 1997
Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN Q. HO**
Program Coordinator