



California Department of Forestry & Fire Protection
Office of the State Fire Marshal
PreFire Engineering
LISTING SERVICE

**Listing Expires
June 30, 1998**



LISTING NO. 7167-0801:106

Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: Radionics, 1800 Abbott Street, Salinas CA 93901
Contact: Mark Hanna (408) 757-8877

DESIGN: Model D4112 fire alarm control unit. Refer to listee's data sheet for detailed product descriptions and operational considerations. Basic components:

D4112	Control/Communicator Panel
D420	Security Control System Keypad
D1625	Class 2 Transformer 16.5 Vac 25 VA
D126	Rechargeable Battery
D4103	Enclosure

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a household fire alarm control unit for use with separately listed compatible initiating and audible devices.

NOTE:

1. Burglary and other non-fire functions were not examined.
2. Formerly 7165-0801:106

This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

ISSUED: JULY 1, 1997
Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN Q. HO**
Program Coordinator