



California Department of Forestry & Fire Protection
Office of the State Fire Marshal
PreFire Engineering
LISTING SERVICE

**Listing Expires
June 30, 1998**



LISTING No. 7272-0801:125

Page 1 of 1

CATEGORY: System Smoke Detectors/Photoelectric

LISTEE: Radionics, 1800 Abbott Street, Salinas CA 93912-0012
Contact: Mark Hanna (408) 757-8877

DESIGN: Models D262, D282 and D283 smoke detectors. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use with separately listed compatible control units.

NOTE:


1. Formerly 7257-0801:125
2. Combined 7270-0801:129 into 7270-0801:125

XLF: 7272-0410:107

Rev. 06-21-94

This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

ISSUED: JULY 1, 1997
Effective issue date to expiration date

AUTHORIZED BY: 
Deputy **BEN Q. HO**
Program Coordinator