



California Department of Forestry & Fire Protection
Office of the State Fire Marshal
PreFire Engineering
LISTING SERVICE

**Listing Expires
June 30, 1998**



LISTING NO. 7300-0801:134

Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Radionics, 1800 Abbott Street, Salinas CA 93912-0012
Contact: Mark Hanna (408) 757-8877

DESCRIPTION: Models D290M and D290S detector base with model D299 auxiliary relay module. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a detector bases with relay module for use with Models D254, D255 heat detectors (CSFM Listing No. 7270-0801:115) or Model D281 ionization smoke detector (CSFM Listing No. 7271-0801:126), Model D262, D282 or D283 photoelectric smoke detectors (CSFM Listing No. 7272-0801:125).

Rev. 06-21-94

This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

ISSUED: JULY 1, 1997
Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN Q. HO**
Program Coordinator