



California Department of Forestry & Fire Protection
Office of the State Fire Marshal
PreFire Engineering
LISTING SERVICE

**Listing Expires
June 30, 1998**



LISTING No.

7125-0801:146

Page 1 of 1

CATEGORY:

Fire Alarm Devices for the Hearing Impaired

LISTEE:

Radionics Inc., 1800 Abbott Street, Salinas, CA 93907
Contact: Mark Hanna (408) 757-8877

DESIGN:

Model D Series, multitone strobe horns with suffixes:

432, *433, (15cd)

422 or *475 (15/75cd) 424, *425 or *425 (30cd) 423 (75cd)

A (60 flashes/min) AL (20 flashes/min-for model 432 only)

Units may follow by suffixes to designate orientation, lettering and plate color. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION:

In accordance with listee's printed instructions and applicable codes and ordinances.

MARKING:

Listee's name, model number, electrical rating and UL label.

APPROVAL:

Listed as a fire alarm signaling device for the hearing impaired when used in conjunction with separately listed compatible fire alarm control units. Model D422 and *475 for wall mount installation only. For indoor use only.

NOTE:

XLF: 7125-0785:122

Rev 12-16-94

This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

ISSUED: JULY 1, 1997

Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN Q. HO**
Program Coordinator