



California Department of Forestry & Fire Protection
Office of the State Fire Marshal
PreFire Engineering
LISTING SERVICE

**Listing Expires
June 30, 1998**



LISTING No.

7125-0801:147

Page 1 of 1

CATEGORY:

Fire Alarm Devices for Hearing Impaired

LISTEE:

Radionics, Inc. 1800 Abbott Street, Salinas, CA 93907
Contact: Mark Hanna (408) 757-8877

DESIGN:

Models **D446** and **D436** strobe lights with suffixes:

A (60 flashes/min)

AL (20 flashes/min).

All models rated at 110cd. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION:

In accordance with listee's printed instructions and applicable codes and ordinances.

MARKING:

Listee's name, model number, electrical rating and UL label.

APPROVAL:

Listed as signaling device for the hearing impaired when used in conjunction with separately listed compatible control units. For wall mount and indoor installation only.

NOTE:

XLf: 7125-0785-119

08-26-94

This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

ISSUED: JULY 1, 1997

Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN Q. HO**
Program Coordinator