



California Department of Forestry & Fire Protection
 Office of the State Fire Marshal
 PreFire Engineering
LISTING SERVICE

**Listing Expires
 June 30, 1998**



LISTING No. 7135-0801:151

Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Radionics Inc, 1800 Abbott Street, Salinas, CA 93901
 Contact: Mark Hanna (408) 757-8877

DESIGN: Model D470 multitone audible device. Unit is switchable between nominal 12 and 24 VDC with high and low output. This series can provide one of nine tone outputs. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: -12: 9 - 15.6 VDC
 -24: 18 - 31 VDC

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as audible signal devices for use with separately listed compatible control units. Suitable for outdoor when installed with weatherproof back box.

XLF: 7135-0785:127

07-11-95

This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

ISSUED: JULY 1, 1997

Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN Q. HO**
 Program Coordinator