



California Department of Forestry & Fire Protection  
Office of the State Fire Marshal  
PreFire Engineering  
**LISTING SERVICE**

**Listing Expires  
June 30, 1998**



**LISTING No.** 7125-0801:152

Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** Radionics Inc., 1800 Abbott Street, Salinas, CA 93901  
Contact: Mark Hanna (408) 757-8877

**DESIGN:** Models D472A, D474A, D476A, D477A, and D478A multitone audible/visual signal devices. Units are switchable between nominal 12 and 24 VDC with high and low output. This series can provide one of nine tone outputs. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**

Electrical:	D472A, D476A: 10.5 - 15.6 VDC D474A, 477A, 478A: 20 - 31 VDC
Strobe Candela:	D472A, D474A: 15 cd, 60 Flashes/min D476A, D477A: 15/75 cd, 60 Flashes/min D478A: 30 cd, 60 Flashes/min

**INSTALLATION:** In accordance with listee's printed installation instructions and applicable codes and ordinances.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as audible/visual signal devices for use with separately listed compatible control units. For indoor use only. Models D472A, D474A and D478A strobes are for wall or ceiling mount; and Models D476A and D477A strobes are for wall mount only.

**XLF:** 7125-0785:128

07-11-95

*This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.*

**ISSUED: JULY 1, 1997**  
Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN Q. HO**  
Program Coordinator