



California Department of Forestry & Fire Protection  
 Office of the State Fire Marshal  
 PreFire Engineering  
**LISTING SERVICE**

**Listing Expires  
 June 30, 1998**



**LISTINGS No.** 7260-0801:154

Page 1 of 1

**CATEGORY:** Beam Smoke Detection System

**LISTEE:** Radionics Inc., 1800 Abbott St., Salinas, CA 93901  
 Contact: Mark Hanna  
 (408) 457-8877

**DESIGN:** Model D295 projected beam smoke detection system. Unit consists of one emitter unit and one receiver unit. Refer to listee's printed data sheet for additional product description and operational consideration.

**INSTALLATION:** In accordance with listee's printed installation instructions and applicable codes and ordinances.

**MARKING:** Listee's name, model number, electrical ratings, and UL Label

**APPROVAL:** Listed as a beam smoke detection system for use with separately listed compatible fire alarm control units.

**XLF:** 7260-0410:141

12-12-95

---

*This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.*

**ISSUED: JULY 1, 1997**  
 Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN Q. HO**  
 Program Coordinator