



California Department of Forestry & Fire Protection  
Office of the State Fire Marshal  
PreFire Engineering  
**LISTING SERVICE**

**Listing Expires  
June 30, 1998**



**LISTING No.**

7125-0801:156

Page 1 of 1

**CATEGORY:**

Fire Alarm Devices for the Hearing Impaired

**LISTEE:**

Radionics Inc., 1800 Abbott St., Salinas, CA 93912-0012  
Contact: Mark Hanna (408) 757-8877 Fax (408) 422-3674

**DESIGN:**

Models D511S, D501S, D513S, D508S, D512S, D503S, D509S and D505S audible strobes. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**

60 (flashes/min)  
D511S, D512S, D513S (10.5-15.6 VDC)  
D501S, D503S, D505S, D508S, D509S (20-31 VDC)  
  
D501S, D511S (15cd)  
D508S, D513S (30cd)  
D503S, D512S (15/75cd)  
D509S (75cd)  
D505S (110cd)

**INSTALLATION:**

In accordance with listee's printed installation instructions and applicable codes and ordinances. All units are suitable for wall or ceiling mount except Models D503S and D512S are for wall mount only.

**MARKING:**

Listee's name, model number, electrical/candela rating and UL label.

**APPROVAL:**

Listed as audible/visual signaling devices suitable for the hearing impaired when used in conjunction with separately listed electrically compatible fire alarm control units. For indoor use only. For synchronization, above models must be used with Model D411, D411LC, D412, or D412LC sync control module.

**XLF:**

7125-0785:131

06-18-96

*This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.*

**ISSUED: JULY 1, 1997**

Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN Q. HO**  
Program Coordinator