



California Department of Forestry & Fire Protection
Office of the State Fire Marshal
PreFire Engineering
LISTING SERVICE

**Listing Expires
June 30, 1998**



LISTING No. 7300-0801:157

Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Radionics Inc., 1800 Abbott St., Salinas, CA 93912-0012
Contact: Mark Hanna (408) 757-8877 Fax (408) 422-3674

DESIGN: Models D411, D411LC, D412, D412LC Synchronized Control Modules.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 10.5 - 31 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as signaling appliances accessory for use with separately listed synchronized strobe lights. For indoor use only.

XLF: 7300-0785:132

06-18-96

This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

ISSUED: JULY 1, 1997
Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN Q. HO**
Program Coordinator