



California Department of Forestry & Fire Protection  
 Office of the State Fire Marshal  
 PreFire Engineering  
**LISTING SERVICE**

**Listing Expires  
 June 30, 1998**



**LISTING No:** 7125-801:158

Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** Radionics Inc., 1800 Abbott Street, Salinas, CA 93912-0012  
 Contact: Mark Hanna (408) 757-8877 Fax (408) 422-3674

**DESIGN:** Strobe Lights Models:

- D444A, D444AL, D445A, D445AL, (15cd)
- D417A, D473A (15/75 cd)
- D426A, D427A, D427AL (30cd)
- D418A (75cd)

Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** No L (60 flashes/min) or L (20 flashes/min)  
**D427, D445, D473** (10.5 - 15.6 VDC)  
**D417, D418, D426, D444** (20-31 VDC)

**INSTALLATION:** In accordance with listee's printed installation instructions and applicable codes and ordinances. Suitable for ceiling/wall mount except for models D417 or D473 series are for wall mount only.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as strobe lights for the hearing impaired when used in conjunction with separately listed electrically compatible fire alarm control units. For indoor use only.


**XLF:** 7125-0785:116

06-18-96

---

*This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.*

**ISSUED: JULY 1, 1997**  
 Effective issue date to expiration date

AUTHORIZED BY:   
 Deputy **BEN Q. HO**  
 Program Coordinator