



California Department of Forestry & Fire Protection  
Office of the State Fire Marshal  
PreFire Engineering  
**LISTING SERVICE**

**Listing Expires  
June 30, 1998**



**LISTING No.** 7272-0801:167

Page 1 of 1

**CATEGORY:** Photoelectric Smoke Detector

**LISTEE:** Radionics, Inc., 1800 Abbott St., Salinas, CA 93901  
Contact: Mark Hanna (408) 757-8877

**DESIGN:** Model D323 photoelectric type smoke detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as photoelectric smoke detector for use with listee's Model D336 and D321 bases (CSFM Listing No. 7300-0801:169) and separately listed electrically compatible fire alarm control units.

**XLf:** 7272-0410:142

10-09-96

---

*This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.*

**ISSUED: JULY 1, 1997**  
Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN Q. HO**  
Program Coordinator