



California Department of Forestry & Fire Protection
 Office of the State Fire Marshal
 PreFire Engineering
LISTING SERVICE

**Listing Expires
 June 30, 1998**



LISTING No. 7271-0801:170

Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Radionics, Inc., 1800 Abbott Street, Salinas, CA 93901
 Contact: Mark Hanna (408) 757-8877

DESIGN: Model D324 ionization type smoke detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.


APPROVAL: Listed as ionization smoke detector for use with listee's Model D336 and D321 bases (CSFM Listing No. 7300-0801:169) and separately listed electrically compatible fire alarm control units.

XLF: 7271-0410:144

10-09-96

This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

ISSUED: JULY 1, 1997
 Effective issue-date to expiration date

AUTHORIZED BY: 
 Deputy **BEN Q. HO**
 Program Coordinator