



California Department of Forestry & Fire Protection  
Office of the State Fire Marshal  
PreFire Engineering  
**LISTING SERVICE**

**Listing Expires  
June 30, 1998**



**LISTING No.** 7300-0801:171

Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** Radionics, 1800 Abbott Street, Salinas, CA 93901  
Contact: Mark Hanna (408) 757-8877

**DESIGN:** Model D327 Bell Module and D334, Monitor Modules. All modules must be used with a \*10K ohm end-of-line resistor for proper supervision. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as control unit accessories for use with separately listed electrically and functionally compatible fire alarm control units.

**XLF:** 7300-0410:145

10-09-96

---

*This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.*

**ISSUED: JULY 1, 1997**  
Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN Q. HO**  
Program Coordinator