



California Department of Forestry & Fire Protection
Office of the State Fire Marshal
PreFire Engineering
LISTING SERVICE

**Listing Expires
June 30, 1998**



LISTING No. 7270-0801:172

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Radionics, Inc., 1800 Abbott Street., Salinas, CA 93901
Contact: Mark Hanna (408) 757-8877

DESIGN: Model D322 electronic fix temperature heat detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 134°F to 149° F Fix Temperature/Rate of Rise

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For ceiling mount only.

MARKING: Listee's name, model number, temperature rating and UL label.

APPROVAL: Listed as fix temperature heat detector for use with listee's Model D321 base (CSFM Listing No. 7300-0801:169) and separately listed Radionics' Model D10024 fire alarm control unit (CSFM Listing No. 7165-0801:166).

XLF: 7272-0410:146

10-09-96

This listing is based upon technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

ISSUED: JULY 1, 1997
Effective issue date to expiration date

AUTHORIZED BY:

Deputy **BEN Q. HO**
Program Coordinator