



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

**Listing Expires
 June 30, 2000**

LISTING SERVICE

LISTING No. 7272-0801:187

Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: Radionics-Div Detection Systems, 130 Perinton Pkwy, Fairport NY, 14450-9199
 Contact: Bruce Gibson (716) 223-4060

DESIGN: Model D323A analog addressable photoelectric type smoke detector with Model D321A base. Unit consists of resistors, capacitors, diodes, transistors, LED, photo diode, mounted on a printed wiring board inside an enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 39.5 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detector for use with separately listed compatible fire alarm control units.

XLF: 7272-0410:149

08-31-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 31, 1999**
 Effective issue date to expiration date

Authorized By:

BEN HO, Deputy State Fire Marshal III
 Program Manager